

Island County Water Well Information



 **WellKey: 8HM**

General Information

Owner Name (log): Ray Gabelein

DOE Tag: AGA660

DOE NOI:

DOE ID

83242

Well Address: 1200' S & 500' E of NW corner Sec. 5

Well Parcel: [R32905-443-0520](#)

Served Parcel:

Horiz/Vert Accuracy: GPS / DEM

Site Type: Well

USGS ID: [480206122273201](#)

SWI Rating: Low Risk

[Click to View
Well Location
in Google
Maps](#)

[Click to View
Well Location
in Google
Earth](#)

Construction Information

Construction Date: 02/10/81

Driller Name: B & W Drilling Co.


LS Elevation: 162 ft. MSL

Depth Well: 161 ft.

TD Elevation: 1 ft. MSL

WL Measurements: [1 measurement \(Click to View\)](#)

WL Elevation: 35 ft. MSL



Water Quality Information

Water Samples: [5 samples \(Click to View\)](#)


Avg/Med/Max Arsenic: 0.009 / 0.009 / 0.009 mg/l

Avg/Med/Max Chloride: 9.70 / 9.7 / 9.7 mg/l

Avg/Med/Max Hardness: 103.30 / 103.3 / 103.3 mg/l

Avg/Med/Max Nitrate: 0.53 / 0.25 / 1.35 mg/l

Bacteria Samps (distribution): [32 samples \(Click to View\)](#)



Public Water System Information

Pws Name: Lone Lake Estates

PwsID: [07841](#)

Approved Connects: 5

Pws Source #: SO# 1

Pws Source Name: WELL #1 AGA660

Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.
Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/30/2020

Depth/
Elev(ft)

0/162

25/137

50/112

75/87

100/62

125/37

150/12

17.5p161/1